



V.V. VANNIAPERUMAL COLLEGE FOR WOMEN MANAGING BOARD

(Belonging to Virudhunagar Hindu Nadars)
VIRUDHUNAGAR - 626 001. (Tamil Nadu)
Registered No. 45/66

P.C.S.GOVINDARAJAPERUMAL, B.A.,
Secretary
Mobile : 98431 95051
e-mail : pcsgovind@yahoo.co.in

Phone : 243540, 265540
Fax : 04562 - 248694
e-mail : officevvvc2014@gmail.com
website : www.vvvcollege.org
www.vanniaperumalcollegeforwomen.com

நாள்: 11.11.2022

பெறுநர்

Assistant Executive Engineer,
TANGEDCO,
Rural,
Virudhunagar.

ஐயா,

வணக்கம், வே.வ.வன்னியப்பெருமாள் பெண்கள் கல்லூரியில் மின் சிக்கனத்தை வலியுறுத்தும் நோக்கில் இவ்வாண்டும் நவம்பர் 2022 (14.11.2022), டிசம்பர் 2022 (22.12.2022) மின்சேமிப்பு தினம் கடைபிடிக்கப்படவுள்ளது. அச்சமயம் எங்கள் கல்லூரியின் மின் அளவீட்டை அவ்விரு நாட்களும் குறித்துத் தருமாறு தாழ்மையுடன் கேட்டுக் கொள்கிறோம்.

நன்றி

இப்படிக்கு

செயலாளர்



V.V.VANNIAPERUMAL COLLEGE FOR WOMEN
(Belonging to Virudhunagar Hindu Nadars)
An Autonomous Institution Affiliated to Madurai Kamaraj University
Re-accredited with 'A' Grade (3rd cycle) by NAAC
Virudhunagar-626 001



INTERNAL QUALITY ASSURANCE CELL



Date: 11.11.2022

CIRCULAR

In continuation of the venture to insist the motto of **Least Power Usage, Lasting Power Storage** among the Faculty and the Students of our college, the Internal Quality Assurance Cell of our College has planned to observe one day as **Electricity Economy Day** in every ~~month~~ *Semester*.

In this regard all the Teaching & Non-Teaching members and the Students are asked to avoid using Lights and Fans in all the Buildings of our college on 14.11.2022 from 09.30 a.m.to 12.40 p.m. as an effort to conserve Electric Power Resources.

Subha
11/11/22
Staff-in-charge

S. S. S. S.
IQAC Coordinator

S. P. Renu Rani
PRINCIPAL





V.V.VANNIAPERUMAL COLLEGE FOR WOMEN

(Belonging to Virudhunagar Hindu Nadars)

An Autonomous Institution Affiliated to Madurai Kamaraj University

Re-accredited with 'A' Grade (3rd cycle) by NAAC

Virudhunagar-626 001

INTERNAL QUALITY ASSURANCE CELL



Electricity Economy Day -14.11.2022

Report

The Internal Quality Assurance Cell of our College observed 'Electricity Economy Day' on 14.11.2022 to create awareness on economic energy consumption among young minds, The Programme was organized by the IQAC members, Dr. Chandrakala, Assistant Professor of History and Mrs. R.Subha, M.Sc., M.Phil., D.C.T., Assistant Professor of Home Science. By comparing the data collected through Meter and Relay Test from the TNEB, TANGEDCO, Virudhunagar, between normal working day and Electricity Economy Day, it was found that approximately 298 units were less consumed.

Electricity Consumption on Normal Working Day Vs Electricity Economy Day

S.No	Date	Duration	Power Consumed (kwh /Units)
1.	16.11.2022 (Normal working day)	9.30 am - 1.00 pm.	0.7758 /465.47
2.	14.11.2022 (Electricity Economy Day)	9.30 am - 1.00 pm.	0.27820 /166.92
Power Saved			0.7758 / 298.55 units

M. Chandra kela
Subha

Staff in charge

IQAC Coordinator

The following are the readings taken in V.V.Vanniaperumal College for Women, HT Service Connection Number - 79094620389 during the Electricity Economy day observed in the campus on 14.11.2022 and a randomly chosen normal working day, 16.11.2022 for a time period of 9.30 am to 1.00 pm.

Date	Duration	Power Consumed (Units)
16.11.2022 (Normal working day)	9.30 am - 1.00 pm.	465.47
14.11.2022 (Electricity Economy Day)	9.30 am - 1.00 pm.	166.92
Power Saved		298.55 units



**Assistant Executive Engineer
Meter and Relay Test,
TANGEDCO,
Virudhunagar – 626001.**

Local Survey - Enrg-14.11.2022

HT SC No. 389, M/s VW College, VNR



Schneider Electric India Private Limited

Load Survey - Energy Report

Meter Details

Make of Meter	L&T	Meter Serial No.	18454132	Consumer Name		PT Ratio	1	Integration Period	15 mins
Meter Version	NTD19.04	Meter Type	2.(3ph-4W) HT PT/CT	Consumer ID		CT Ratio	1	Number of Days	1
VinPlus Version	TN_VinPlus 2.6.1	Meter Location							
Data Dump Time(PC)	08/12/2022 09:56:26	Data Read Time (MRI/PC)	06/12/2022 17:50:11	Data Read Time (Meter)	06/12/2022 16:41:35	Collection			
Anomaly	A000000000000000								
Supported Parameters	RI, YI, BI, RV, YV, BV, Fwd.kWh, Fwd.kVAhLag, Fwd.kVAhLead, Fwd.kVAh, AvgFrequency, PF							Utility Name	
Association Mode	1.(Meter Reader)	Logical Device Name	LNTM4XXXXXXC5	Manufactured Info	2018	Name Plate Details		HT 63.5V CL 0.2(ACTIVE) 0.2(REACTIVE) Ib-5A	
CT Rating	5-10A	Category	HT(PT/CT operated) <(CT operated)-C1						

Date	Time ---> Parameter Total	00:15:00	00:30:00	00:45:00	01:00:00	01:15:00	01:30:00	01:45:00	02:00:00	02:15:00	02:30:00	02:45:00	03:00:00	03:15:00	03:30:00	03:45:00	04:00:00	04:15:00	04:30:00	04:45:00	05:00:00	05:15:00	05:30:00	05:45:00	06:00:00
14/11/2022	R Current (A)	0.494	0.496	0.507	0.501	0.485	0.489	0.486	0.498	0.488	0.484	0.470	0.472	0.466	0.481	0.485	0.475	0.478	0.504	0.526	0.627	0.637	0.666	0.685	0.756
	Y Current (A)	0.488	0.488	0.478	0.474	0.474	0.486	0.478	0.473	0.463	0.474	0.474	0.461	0.461	0.462	0.468	0.453	0.455	0.494	0.513	0.609	0.629	0.678	0.723	0.806
	B Current (A)	0.561	0.567	0.577	0.564	0.553	0.557	0.560	0.567	0.554	0.554	0.552	0.538	0.529	0.541	0.549	0.532	0.529	0.567	0.579	0.659	0.675	0.726	0.776	0.801
	R Voltage(V)	66.85	66.81	66.82	66.76	66.76	66.99	67.00	67.08	67.14	67.18	67.18	67.10	67.03	67.01	67.01	66.90	66.83	66.78	66.73	66.53	66.44	66.78	66.49	
	Y Voltage(V)	66.81	66.75	66.74	66.68	66.74	66.92	66.94	67.04	67.14	67.21	67.19	67.10	67.07	67.05	66.92	66.81	66.71	66.76	66.73	66.54	66.42	66.76	66.46	
	B Voltage(V)	66.25	66.28	66.26	66.29	66.24	66.48	66.49	66.54	66.56	66.60	66.60	66.65	66.51	66.48	66.46	66.51	66.44	66.36	66.26	66.17	65.96	65.86	66.22	65.94
	Fwd.kWh 3.53551	0.02562	0.02572	0.02591	0.02551	0.02506	0.02552	0.02538	0.02563	0.02508	0.02523	0.02495	0.02453	0.02426	0.02472	0.02502	0.02429	0.02429	0.02597	0.02655	0.03112	0.03210	0.03391	0.03590	0.03876
	Fwd.kVAhLag 0.44905	0.00063	0.00072	0.00073	0.00061	0.00055	0.00065	0.00077	0.00073	0.00046	0.00056	0.00068	0.00045	0.00043	0.00044	0.00054	0.00034	0.00068	0.00223	0.00402	0.00409	0.00297	0.00412	0.00472	0.00438
	Fwd.kVAhLead 0.03633	0.00089	0.00091	0.00111	0.00107	0.00106	0.00084	0.00086	0.00107	0.00120	0.00112	0.00121	0.00124	0.00114	0.00108	0.00101	0.00118	0.00089	0.00009	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000
	Fwd.kVAh 3.60328	0.02571	0.02582	0.02604	0.02562	0.02517	0.02561	0.02550	0.02574	0.02520	0.02534	0.02508	0.02464	0.02435	0.02482	0.02511	0.02440	0.02439	0.02615	0.02696	0.03159	0.03236	0.03431	0.03640	0.03920

Assistant Executive Engineer,
Meter and Relay Test,
TANGEDCO,
Virudhunagar - 626 001.



HT SC.No. 389, M/S VVV College, VNR

Date	Time ---> Parameter Total	06:15:00	06:30:00	06:45:00	07:00:00	07:15:00	07:30:00	07:45:00	08:00:00	08:15:00	08:30:00	08:45:00	09:00:00	09:15:00	09:30:00	09:45:00	10:00:00	10:15:00	10:30:00	10:45:00	11:00:00	11:15:00	11:30:00	11:45:00	12:00:00
14/11/2022	R Current (A)	0.737	0.671	0.701	0.703	0.708	0.756	0.727	0.724	0.818	0.836	0.688	0.797	0.844	0.751	0.636	0.472	0.156	0.115	0.168	0.152	0.260	0.270	0.274	0.345
	Y Current (A)	0.815	0.723	0.762	0.767	0.789	0.827	0.803	0.810	0.862	0.878	0.760	0.848	0.912	0.794	0.696	0.514	0.181	0.109	0.195	0.178	0.296	0.297	0.294	0.379
	B Current (A)	0.816	0.752	0.785	0.782	0.806	0.855	0.812	0.813	0.887	0.866	0.675	0.779	0.877	0.807	0.691	0.496	0.139	0.100	0.202	0.177	0.270	0.303	0.291	0.372
	R Voltage(V)	65.89	65.01	64.49	64.12	63.86	63.81	63.90	63.99	63.96	63.98	64.03	64.01	63.70	63.77	63.43	63.08	62.74	62.63	62.53	62.66	62.66	62.71	62.70	62.60
	Y Voltage(V)	65.87	65.06	64.54	64.16	63.93	63.87	63.97	64.07	64.07	64.12	64.12	64.12	63.87	63.98	63.66	63.26	62.94	62.86	62.79	62.97	62.85	62.88	62.90	62.82
	B Voltage(V)	65.37	64.62	64.15	63.73	63.50	63.45	63.48	63.62	63.69	63.71	63.79	63.78	63.43	63.55	63.14	62.83	62.51	62.36	62.32	62.43	62.41	62.47	62.50	62.43
	Fwd.kWh 3.53551	0.03871	0.03461	0.03610	0.03591	0.03653	0.03854	0.03708	0.03714	0.04027	0.04072	0.03360	0.03803	0.04138	0.03717	0.03171	0.02293	0.00591	0.00394	0.00795	0.00709	0.01246	0.01303	0.01277	0.01651
	Fwd.kVAhlag 0.44905	0.00222	0.00095	0.00131	0.00123	0.00241	0.00416	0.00353	0.00414	0.00671	0.00561	0.00342	0.00587	0.00501	0.00239	0.00165	0.00006	0.00042	0.00102	0.00223	0.00229	0.00175	0.00195	0.00241	0.00190
	Fwd.kVAhlead 0.03633	0.00028	0.00055	0.00015	0.00029	0.00020	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00002	0.00033	0.00098	0.00255	0.00063	0.00007	0.00003	0.00007	0.00001	0.00000	0.00022
	Fwd.kVAh 3.60328	0.03900	0.03479	0.03628	0.03610	0.03681	0.03892	0.03740	0.03753	0.04104	0.04130	0.03402	0.03872	0.04200	0.03754	0.03214	0.02341	0.00761	0.00515	0.00886	0.00797	0.01296	0.01365	0.01343	0.01719

Assistant Executive Engineer,
Meter and Relay Test,
TANGEDCO,
Virudhunagar - 626 001

Assistant Executive Engineer,
Meter and Relay Test,
TANGEDCO,
Virudhunagar - 626 001



HT SC No. 389, M/s VVV College, Virudhunagar

Date	Time ---> Parameter Total	12:15:00	12:30:00	12:45:00	13:00:00	13:15:00	13:30:00	13:45:00	14:00:00	14:15:00	14:30:00	14:45:00	15:00:00	15:15:00	15:30:00	15:45:00	16:00:00	16:15:00	16:30:00	16:45:00	17:00:00	17:15:00	17:30:00	17:45:00	18:00:00
14/11/2022	R Current (A)	0.449	0.349	0.515	0.972	1.158	1.151	1.293	1.367	1.395	1.540	1.511	1.594	1.619	1.616	1.531	1.506	1.442	1.364	1.286	1.249	1.149	0.977	0.953	0.803
	Y Current (A)	0.500	0.392	0.568	0.924	1.083	1.100	1.257	1.392	1.435	1.591	1.474	1.603	1.654	1.596	1.568	1.522	1.493	1.416	1.366	1.306	1.179	1.013	0.942	0.794
	B Current (A)	0.500	0.407	0.543	0.888	1.094	1.112	1.264	1.444	1.450	1.575	1.485	1.613	1.717	1.668	1.648	1.588	1.534	1.430	1.347	1.326	1.221	1.060	1.014	0.834
	R Voltage(V)	62.62	62.46	62.61	62.74	63.09	63.40	63.64	63.83	63.84	63.39	63.22	63.24	63.27	63.25	63.17	63.17	63.57	63.37	63.27	63.11	63.07	62.95	62.83	62.48
	Y Voltage(V)	62.82	62.67	62.80	62.90	63.23	63.54	63.79	63.94	63.90	63.42	63.27	63.24	63.32	63.26	63.17	63.16	63.58	63.35	63.29	63.08	63.02	62.86	62.72	62.46
	B Voltage(V)	62.33	62.18	62.33	62.50	62.79	63.07	63.30	63.46	63.45	62.99	62.78	62.81	62.88	62.95	62.87	62.91	63.30	63.10	62.93	62.69	62.67	62.54	62.44	62.09
	Fwd.kWh 3.53551	0.02213	0.01743	0.02504	0.04213	0.05045	0.05122	0.05877	0.06453	0.06527	0.07169	0.06822	0.07305	0.07659	0.07551	0.07320	0.07121	0.06916	0.06489	0.06161	0.05962	0.05466	0.04734	0.04477	0.03715
	Fwd.kVARhlag 0.44905	0.00341	0.00055	0.00177	0.00800	0.01128	0.01125	0.01004	0.01534	0.01701	0.01724	0.01506	0.01786	0.01587	0.01236	0.01196	0.01240	0.01296	0.01126	0.01124	0.01083	0.00857	0.00503	0.00773	0.00663
	Fwd.kVAHlead 0.03633	0.00000	0.00068	0.00034	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000
	Fwd.kVAh 3.60328	0.02276	0.01790	0.02552	0.04356	0.05250	0.05332	0.06053	0.06707	0.06817	0.07439	0.07053	0.07580	0.07886	0.07709	0.07478	0.07291	0.07098	0.06651	0.06324	0.06115	0.05584	0.04792	0.04564	0.03794

Assistant Executive Engineer,
Meter and Relay Test,
TANGEDCO,
Virudhunagar - 626 001.Assistant Executive Engineer,
Meter and Relay Test,
TANGEDCO,
Virudhunagar - 626 001.Assistant Executive Engineer,
Meter and Relay Test,
TANGEDCO,
Virudhunagar - 626 001.



HT SC.NO.389, M/S VVV College, VNR

Date	Time --- > Parameter Total	18:15:00	18:30:00	18:45:00	19:00:00	19:15:00	19:30:00	19:45:00	20:00:00	20:15:00	20:30:00	20:45:00	21:00:00	21:15:00	21:30:00	21:45:00	22:00:00	22:15:00	22:30:00	22:45:00	23:00:00	23:15:00	23:30:00	23:45:00	24:00:00
14/11/2022	R Current (A)	0.837	0.918	1.001	1.006	0.975	0.934	0.738	0.877	0.897	0.920	0.900	0.870	0.836	0.789	0.739	0.609	0.600	0.563	0.550	0.544	0.543	0.565	0.535	0.531
	Y Current (A)	0.821	0.919	0.972	0.976	0.918	0.860	0.705	0.840	0.880	0.922	0.878	0.858	0.829	0.776	0.704	0.575	0.600	0.546	0.546	0.532	0.526	0.524	0.510	0.521
	B Current (A)	0.901	1.002	1.074	1.068	1.028	0.995	0.813	0.937	0.954	1.013	0.973	0.942	0.917	0.860	0.806	0.656	0.679	0.629	0.624	0.619	0.621	0.635	0.603	0.587
	R Voltage(V)	62.42	62.44	62.71	63.01	63.32	63.60	64.19	64.26	64.58	64.62	63.91	64.05	64.26	64.35	64.56	64.89	64.93	65.14	65.14	65.37	65.49	65.69	65.85	65.94
	Y Voltage(V)	62.34	62.42	62.65	62.95	63.27	63.56	64.11	64.15	64.50	64.56	63.86	64.01	64.22	64.37	64.58	64.91	64.93	65.08	65.10	65.30	65.36	65.62	65.82	65.94
	B Voltage(V)	62.11	62.10	62.37	62.69	62.98	63.25	63.81	63.85	64.08	64.11	63.43	63.58	63.81	63.98	64.24	64.46	64.48	64.69	64.76	64.94	65.06	65.12	65.24	65.35
	Fwd.kWh 3.53551	0.03935	0.04383	0.04716	0.04737	0.04567	0.04240	0.02942	0.04177	0.04323	0.04524	0.04297	0.04207	0.04085	0.03846	0.03601	0.02969	0.03028	0.02819	0.02788	0.02755	0.02750	0.02804	0.02695	0.02687
	Fwd.kVAhlag 0.44905	0.00471	0.00436	0.00538	0.00619	0.00623	0.00509	0.00536	0.00710	0.00723	0.00818	0.00733	0.00695	0.00575	0.00435	0.00265	0.00047	0.00053	0.00075	0.00054	0.00046	0.00058	0.00077	0.00068	0.00062
	Fwd.kVAhlead 0.03633	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00004	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00047	0.00108	0.00155	0.00082	0.00118	0.00138	0.00135	0.00123	0.00108	0.00070
	Fwd.kVAh 3.60328	0.03983	0.04424	0.04767	0.04796	0.04631	0.04294	0.03012	0.04253	0.04400	0.04617	0.04374	0.04284	0.04142	0.03890	0.03632	0.02984	0.03044	0.02830	0.02798	0.02768	0.02763	0.02817	0.02707	0.02694

Assistant Executive Engineer,
Meter and Relay Test,
TANGEDCO,
Virudhunagar - 626 001.



Schneider Electric India Private Limited

Daily Details

Date	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	RI	YI	BI	RV	YV	BV
Max.Value	0.0440	0.0435	0.0069	0.0023	0.946	0.898	0.980	66.91	66.94	66.36
Consumption	2.7330	2.7048	0.1862	0.0565	*	*	*	*	*	*
13/11/2022										
Min.Value	0.0167	0.0162	0.0000	0.0000	0.341	0.314	0.365	64.50	64.39	64.05
Max.Value	0.0463	0.0452	0.0087	0.0029	0.937	0.909	1.024	66.83	66.86	66.33
Consumption	2.8417	2.8156	0.1869	0.0606	*	*	*	*	*	*
14/11/2022										
Min.Value	0.0052	0.0039	0.0001	0.0000	0.115	0.109	0.100	62.42	62.34	62.09
Max.Value	0.0789	0.0766	0.0179	0.0026	1.619	1.654	1.717	67.18	67.21	66.65
Consumption	3.6033	3.5355	0.4491	0.0363	*	*	*	*	*	*
15/11/2022										
Min.Value	0.0254	0.0253	0.0004	0.0000	0.498	0.469	0.560	61.68	61.51	61.20
Max.Value	0.0707	0.0689	0.0123	0.0017	1.589	1.535	1.464	66.44	66.47	65.91
Consumption	4.2616	4.2021	0.4754	0.0237	*	*	*	*	*	*
16/11/2022										
Min.Value	0.0257	0.0256	0.0003	0.0000	0.497	0.492	0.570	61.75	61.58	61.37
Max.Value	0.0928	0.0900	0.0205	0.0017	1.995	1.921	1.975	66.19	66.16	65.62
Consumption	4.7450	4.6547	0.6804	0.0221	*	*	*	*	*	*
17/11/2022										
Min.Value	0.0082	0.0080	0.0000	0.0000	0.155	0.151	0.195	61.52	61.54	61.23
Max.Value	0.0755	0.0727	0.0187	0.0036	1.626	1.602	1.612	65.54	65.51	65.10
Consumption	3.1702	3.0956	0.4228	0.0659	*	*	*	*	*	*
18/11/2022										
Min.Value	0.0025	0.0018	0.0000	0.0000	0.036	0.055	0.058	61.77	61.91	61.47
Max.Value	0.0300	0.0294	0.0033	0.0039	0.674	0.671	0.621	66.26	66.26	65.57
Consumption	1.2744	1.2321	0.0613	0.0857	*	*	*	*	*	*
19/11/2022										
Min.Value	0.0024	0.0021	0.0000	0.0000	0.038	0.053	0.053	62.27	62.13	61.88
Max.Value	0.0119	0.0117	0.0039	0.0010	0.238	0.244	0.275	65.75	65.75	65.19
Consumption	0.6782	0.6484	0.0777	0.0408	*	*	*	*	*	*
20/11/2022										
Min.Value	0.0023	0.0019	0.0000	0.0000	0.036	0.048	0.053	63.03	63.29	62.71
Max.Value	0.0407	0.0400	0.0067	0.0025	0.824	0.794	0.912	66.30	66.33	65.74

HT SC. No. 389,
M/S VVV College, VNR

Assistant Executive Engineer,
Meter and Relay Test,
TANGEDCO,
Virudhunagar - 626 001.



Schneider Electric India Private Limited

Daily Details

HT SC.No. 389,
VVV College, VNR

Date	Fwd.kVAh	Fwd.kWh	Fwd.kVAhLag	Fwd.kVAhLead	RI	YI	BI	RV	YV	BV
Min.Value	0.0148	0.0146	0.0005	0.0000	0.484	0.476	0.555	60.37	60.32	59.94
Max.Value	0.1002	0.0971	0.0235	0.0016	2.207	2.232	2.120	66.15	66.11	65.58
Consumption	5.1677	5.0668	0.7957	0.0180	*	*	*	*	*	*
05/11/2022										
Min.Value	0.0206	0.0203	0.0004	0.0000	0.387	0.380	0.489	62.43	62.32	61.99
Max.Value	0.0886	0.0857	0.0222	0.0020	1.867	1.903	1.865	66.29	66.31	65.86
Consumption	3.9262	3.8552	0.5201	0.0343	*	*	*	*	*	*
06/11/2022										
Min.Value	0.0147	0.0144	0.0000	0.0000	0.284	0.287	0.302	64.19	64.35	63.83
Max.Value	0.0494	0.0484	0.0094	0.0030	0.985	0.978	1.085	66.76	66.67	66.26
Consumption	2.8782	2.8423	0.2798	0.0424	*	*	*	*	*	*
07/11/2022										
Min.Value	0.0241	0.0240	0.0006	0.0000	0.469	0.446	0.528	62.00	61.91	61.59
Max.Value	0.0754	0.0733	0.0190	0.0013	1.641	1.598	1.555	66.90	66.82	66.41
Consumption	4.3125	4.2231	0.6360	0.0201	*	*	*	*	*	*
08/11/2022										
Min.Value	0.0260	0.0259	0.0005	0.0000	0.501	0.505	0.572	61.63	61.43	61.26
Max.Value	0.0733	0.0716	0.0152	0.0016	1.533	1.618	1.528	65.96	65.97	65.55
Consumption	4.2578	4.1885	0.5283	0.0281	*	*	*	*	*	*
09/11/2022										
Min.Value	0.0148	0.0145	0.0004	0.0000	0.470	0.474	0.540	62.08	62.11	61.86
Max.Value	0.0775	0.0751	0.0170	0.0016	1.627	1.606	1.675	65.58	65.56	65.21
Consumption	4.2878	4.2176	0.5492	0.0204	*	*	*	*	*	*
10/11/2022										
Min.Value	0.0196	0.0192	0.0004	0.0000	0.522	0.529	0.599	61.92	61.69	61.48
Max.Value	0.0854	0.0830	0.0195	0.0013	1.747	1.861	1.846	65.98	65.93	65.37
Consumption	4.6905	4.6022	0.6570	0.0234	*	*	*	*	*	*
11/11/2022										
Min.Value	0.0000	0.0000	0.0000	0.0000	0.464	0.456	0.491	62.54	62.41	62.11
Max.Value	0.0871	0.0852	0.0186	0.0042	1.792	1.880	1.863	66.43	66.44	65.87
Consumption	4.4802	4.3785	0.7350	0.0191	*	*	*	*	*	*
12/11/2022										
Min.Value	0.0141	0.0140	0.0000	0.0000	0.273	0.277	0.300	62.55	62.45	62.12

Assistant Executive Engineer,
Meter and Relay Test,
TANGEDCO,
Virudhunagar - 626 001.