



V.V.VANNIAPERUMAL COLLEGE FOR WOMEN
(Belonging to Virudhunagar Hindu Nadars)
An Autonomous Institution Affiliated to Madurai Kamaraj University
Re-accredited with 'A' Grade (3rd cycle) by NAAC
Virudhunagar-626 001



INTERNAL QUALITY ASSURANCE CELL



Date: 21.12.2022

CIRCULAR

Electricity Economy Day

In continuation of the venture to insist the motto of **Least Power Usage, Lasting Power Storage** among the Faculty and the Students of our college, the Internal Quality Assurance Cell of our College has planned to observe one day as **Electricity Economy Day** in every semester.

In this regard all the Teaching & Non-Teaching members and the Students are asked to avoid using Lights and Fans in all the Buildings of our college on 22.12.2022 from 09.30 a.m.to 01.00 p.m. as an effort to conserve Electric Power Resources.

M. Chandrasekhar
Bubba
Staff-in-charge

S. Lita
21/12/2022
IQAC Coordinator

S. H. Meena Rani
PRINCIPAL





V.V.VANNIAPERUMAL COLLEGE FOR WOMEN

(Belonging to Virudhunagar Hindu Nadars)

An Autonomous Institution Affiliated to Madurai Kamaraj University

Re-accredited with 'A' Grade (3rd cycle) by NAAC

Virudhunagar-626 001

INTERNAL QUALITY ASSURANCE CELL



Electricity Economy Day - 22.12.2022

Report

The Internal Quality Assurance Cell of our College observed 'Electricity Economy Day' on 22.12.2022 to create awareness on economic energy consumption among young minds. The Programme was organised by the IQAC members, Dr. Chandrakala, Assistant Professor of History and Mrs. R.Subha, M.Sc., M.Phil., D.C.T., Assistant Professor of Home Science. By comparing the data collected through Meter and Relay Test from the TNEB, TANGEDCO, Virudhunagar, between a normal working day and the Electricity Economy Day, it is found that approximately 263 units were less consumed.

Electricity Consumption on Normal Working Day Vs Electricity Economy Day

S.No	Date	Duration	Power Consumed (kwh /Units)
1.	23.12.2022 (Normal working day)	9.30 am - 1.00 pm.	0.61648 / 369
2.	22.12.2022 (Electricity Economy Day)	9.30 am - 1.00 pm.	0.17658/ 105.95
Power Saved			0.4399/ 263.94 units

M. Chandra kela

Subha

Staff in charge

X. Sita

IQAC Coordinator

The following are the readings taken in V.V.Vanniaperumal College for Women, HT Service Connection Number - 79094620389 during the Electricity Economy day observed in the campus on 22.12.2022 and a randomly chosen normal working day, 23.12.2022 for a time period of 9.30 am to 1.00 pm.

Date	Duration	Power Consumed (Units)
23.12.2022 (Normal working day)	9.30 am - 1.00 pm.	369
22.12.2022 (Electricity Economy Day)	9.30 am - 1.00 pm.	105.95
	Power Saved	263.94 units

H. S. Srinivasan
15/6/23

**Assistant Executive Engineer
Meter and Relay Test,
TANGEDCO,
Virudhunagar – 626001.**

Load Survey Energy - 22.12.2022

Reading Details pertaining to HT SC No. 389, M/s V.V.Vanniaperumal College for women,
Virudhunagar.



Schneider Electric India Private Limited

Load Survey - Energy Report

Meter Details

Make of Meter	L&T	Meter Serial No.	18454132	Consumer Name		PT Ratio	1	Integration Period	15 mins
Meter Version	NTD19.04	Meter Type	2,(3ph-4W) HT PT/CT	Consumer ID		CT Ratio	1	Number of Days	1
VinPlus Version	TN_VinPlus 2.6.1	Meter Location							
Data Dump Time(PC)	03/01/2023 10:26:54	Data Read Time (MRI/PC)	02/01/2023 15:19:33	Data Read Time (Meter)	02/01/2023 14:08:40	Collection			
Anomaly	A0yyyyyyyyyy000								
Supported Parameters	RI, YI, BI, RV, YV, BV, Fwd.kWh, Fwd.kVAhLag, Fwd.kVAhLead, Fwd.kVAh, AvgFrequency, PF							Utility Name	
Association Mode	1,(Meter Reader)	Logical Device Name	LNTM4XXXXXXC5	Manufactured Info	2018	Name Plate Details		HT 63.5V CL 0.2(ACTIVE) 0.2(REACTIVE) Ib-5A L	
CT Rating	5-10A	Category	HT(PT/CT operated)<(CT operated)-C1						

Date	Time --> Parameter Total	00:15:00	00:30:00	00:45:00	01:00:00	01:15:00	01:30:00	01:45:00	02:00:00	02:15:00	02:30:00	02:45:00	03:00:00	03:15:00	03:30:00	03:45:00	04:00:00	04:15:00	04:30:00	04:45:00	05:00:00	05:15:00	05:30:00	05:45:00	06:00:00
22/12/2022	R Current (A)	0.512	0.523	0.535	0.510	0.507	0.508	0.514	0.505	0.513	0.512	0.509	0.503	0.508	0.507	0.508	0.510	0.520	0.515	0.561	0.622	0.652	0.643	0.675	0.650
	Y Current (A)	0.509	0.514	0.512	0.521	0.515	0.523	0.517	0.515	0.513	0.510	0.517	0.515	0.516	0.508	0.512	0.509	0.518	0.505	0.563	0.628	0.665	0.630	0.631	0.678
	B Current (A)	0.592	0.601	0.609	0.579	0.576	0.577	0.584	0.579	0.578	0.581	0.576	0.573	0.570	0.575	0.581	0.580	0.585	0.587	0.641	0.697	0.732	0.709	0.702	0.705
	R Voltage(V)	64.76	64.76	64.75	64.69	64.83	64.80	64.78	64.82	64.87	64.86	64.81	64.92	64.93	64.98	64.99	65.06	65.01	64.94	64.89	64.91	65.07	64.90	64.76	64.33
	Y Voltage(V)	64.71	64.64	64.62	64.56	64.72	64.73	64.72	64.76	64.76	64.71	64.69	64.87	64.87	64.87	64.87	65.00	64.94	64.87	64.87	64.87	64.98	64.81	64.65	64.26
	B Voltage(V)	64.18	64.19	64.19	64.23	64.30	64.22	64.19	64.21	64.35	64.37	64.33	64.42	64.43	64.44	64.44	64.47	64.42	64.41	64.35	64.33	64.54	64.40	64.26	63.84
	Fwd.kWh 3.18864	0.02597	0.02629	0.02661	0.02595	0.02573	0.02596	0.02603	0.02569	0.02588	0.02589	0.02579	0.02571	0.02576	0.02572	0.02580	0.02590	0.02624	0.02593	0.02833	0.03140	0.03303	0.03187	0.03233	0.03254
	Fwd.kVAhlag 0.32998	0.00062	0.00062	0.00092	0.00069	0.00063	0.00069	0.00073	0.00072	0.00057	0.00063	0.00065	0.00069	0.00059	0.00065	0.00068	0.00067	0.00106	0.00129	0.00290	0.00176	0.00308	0.00209	0.00156	0.00214
	Fwd.kVAhlead 0.05694	0.00115	0.00106	0.00089	0.00054	0.00071	0.00062	0.00064	0.00068	0.00075	0.00074	0.00059	0.00062	0.00060	0.00067	0.00071	0.00074	0.00047	0.00051	0.00014	0.00015	0.00001	0.00021	0.00021	0.00002
	Fwd.kVAh 3.24304	0.02608	0.02640	0.02672	0.02601	0.02580	0.02604	0.02610	0.02577	0.02594	0.02597	0.02585	0.02578	0.02582	0.02579	0.02587	0.02597	0.02633	0.02603	0.02862	0.03160	0.03330	0.03209	0.03247	0.03272

Assistant Executive Engineer,
Meter and Relay Test,
TANGEDCO,
Virudhunagar - 626 001.



HT SC. No. 389,
M/s VV College, VNR

Date	Time --> Parameter Total	06:15:00	06:30:00	06:45:00	07:00:00	07:15:00	07:30:00	07:45:00	08:00:00	08:15:00	08:30:00	08:45:00	09:00:00	09:15:00	09:30:00	09:45:00	10:00:00	10:15:00	10:30:00	10:45:00	11:00:00	11:15:00	11:30:00	11:45:00	12:00:00
22/12/2022	R Current (A)	0.598	0.596	0.654	0.696	0.748	0.782	0.785	0.733	0.754	0.777	0.722	0.672	0.994	0.762	0.419	0.324	0.274	0.256	0.231	0.238	0.237	0.223	0.232	0.226
	Y Current (A)	0.646	0.651	0.735	0.728	0.777	0.806	0.806	0.767	0.801	0.815	0.767	0.813	1.068	0.810	0.395	0.296	0.262	0.248	0.228	0.228	0.234	0.202	0.230	0.217
	B Current (A)	0.669	0.685	0.754	0.737	0.797	0.835	0.832	0.817	0.837	0.864	0.754	0.776	1.011	0.728	0.347	0.276	0.220	0.196	0.174	0.180	0.175	0.172	0.175	0.170
	R Voltage(V)	64.18	63.49	63.24	62.59	62.37	62.36	62.72	62.89	63.11	63.10	62.80	62.72	62.27	61.78	61.60	61.74	61.59	61.23	61.27	61.39	61.55	61.66	61.64	61.62
	Y Voltage(V)	64.12	63.39	63.12	62.46	62.28	62.28	62.63	62.86	63.08	63.20	62.89	62.75	62.29	61.79	61.61	61.73	61.66	61.28	61.30	61.42	61.62	61.75	61.73	61.71
	B Voltage(V)	63.74	63.05	62.82	62.19	61.99	61.97	62.33	62.60	62.79	62.67	62.38	62.22	61.76	61.26	61.06	61.22	61.12	60.84	60.81	60.92	61.10	61.28	61.29	61.26
	Fwd.kWh 3.18864	0.03050	0.03054	0.03368	0.03348	0.03576	0.03728	0.03773	0.03616	0.03734	0.03813	0.03478	0.03470	0.04693	0.03504	0.01671	0.01282	0.01022	0.00958	0.00832	0.00871	0.00842	0.00833	0.00901	0.00864
	Fwd.kVAhlag 0.32998	0.00237	0.00134	0.00145	0.00306	0.00447	0.00516	0.00427	0.00285	0.00400	0.00572	0.00470	0.00498	0.00754	0.00245	0.00006	0.00000	0.00000	0.00001	0.00002	0.00001	0.00000	0.00007	0.00016	0.00027
	Fwd.kVAhlead 0.05694	0.00003	0.00013	0.00038	0.00001	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00036	0.00302	0.00300	0.00379	0.00258	0.00276	0.00274	0.00344	0.00152	0.00135	0.00124
	Fwd.kVAh 3.24304	0.03069	0.03068	0.03381	0.03373	0.03615	0.03775	0.03805	0.03638	0.03765	0.03868	0.03524	0.03533	0.04784	0.03555	0.01783	0.01383	0.01167	0.01071	0.00973	0.00991	0.00994	0.00923	0.00982	0.00946

Assistant Executive Engineer
Meter and Relay Test
TANGEDCO
Virudhunagar - 626 01

Assistant Executive Engineer
Meter and Relay Test
TANGEDCO
Virudhunagar - 626 01



HT SC.No.389, M/s V.V.Vanniarperumal College, VNR.

Date	Time ---> Parameter Total	12:15:00	12:30:00	12:45:00	13:00:00	13:15:00	13:30:00	13:45:00	14:00:00	14:15:00	14:30:00	14:45:00	15:00:00	15:15:00	15:30:00	15:45:00	16:00:00	16:15:00	16:30:00	16:45:00	17:00:00	17:15:00	17:30:00	17:45:00	18:00:00
22/12/2022	R Current (A)	0.238	0.227	0.233	0.345	0.538	0.974	1.262	1.441	1.539	1.625	1.622	1.473	1.327	1.317	1.152	1.111	1.041	0.956	0.928	1.096	1.143	1.028	0.813	0.719
	Y Current (A)	0.216	0.202	0.207	0.314	0.572	1.094	1.322	1.455	1.559	1.614	1.573	1.474	1.367	1.341	1.221	1.220	1.108	1.028	1.028	1.186	1.202	1.014	0.840	0.759
	B Current (A)	0.182	0.174	0.183	0.295	0.527	1.024	1.278	1.385	1.497	1.577	1.585	1.450	1.345	1.295	1.160	1.147	1.071	0.993	0.957	1.098	1.139	0.980	0.808	0.782
	R Voltage(V)	61.82	61.79	61.89	62.06	62.59	62.45	62.67	62.82	62.99	63.34	63.72	63.73	63.55	63.34	63.25	62.94	63.08	62.81	62.63	62.38	62.01	61.83	61.85	61.83
	Y Voltage(V)	61.91	61.86	61.98	62.17	62.70	62.55	62.77	62.94	63.10	63.42	63.79	63.80	63.61	63.39	63.28	62.97	63.06	62.80	62.58	62.31	61.92	61.71	61.74	61.72
	B Voltage(V)	61.50	61.51	61.59	61.71	62.22	62.14	62.35	62.51	62.64	62.98	63.41	63.33	63.13	62.88	62.79	62.50	62.60	62.31	62.13	61.86	61.45	61.28	61.36	61.33
	Fwd.kWh 3.18864	0.00914	0.00851	0.00897	0.01416	0.02483	0.04676	0.05916	0.06537	0.07044	0.07444	0.07422	0.06843	0.06257	0.06120	0.05466	0.05345	0.04974	0.04581	0.04427	0.05133	0.05254	0.04613	0.03766	0.03403
	Fwd.kVAhlag 0.32998	0.00061	0.00011	0.00069	0.00206	0.00392	0.00922	0.01035	0.01308	0.01388	0.01367	0.01418	0.01178	0.00943	0.00969	0.00788	0.00830	0.00670	0.00524	0.00731	0.00902	0.00881	0.00476	0.00189	0.00646
	Fwd.kVAhlead 0.05694	0.00047	0.00105	0.00045	0.00002	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00001	0.00009	0.00000
Fwd.kVAh 3.24304	0.00984	0.00931	0.00966	0.01478	0.02560	0.04814	0.06047	0.06718	0.07229	0.07619	0.07606	0.07003	0.06386	0.06256	0.05574	0.05458	0.05072	0.04668	0.04547	0.05264	0.05371	0.04675	0.03788	0.03483	

Assistant Executive Engineer,
Meter and Relay Test,
TANGEDCO,
Virudhunagar - 626 001.Assistant Executive Engineer,
Meter and Relay Test,
TANGEDCO,
Virudhunagar - 626 001.



HT-SC.No. 389

M/S VVV College, VNR

Date	Time --> Parameter Total	18:15:00	18:30:00	18:45:00	19:00:00	19:15:00	19:30:00	19:45:00	20:00:00	20:15:00	20:30:00	20:45:00	21:00:00	21:15:00	21:30:00	21:45:00	22:00:00	22:15:00	22:30:00	22:45:00	23:00:00	23:15:00	23:30:00	23:45:00	24:00:00
22/12/2022	R Current (A)	0.872	0.918	0.933	0.862	0.863	0.812	0.817	0.846	0.811	0.785	0.748	0.709	0.648	0.649	0.645	0.587	0.585	0.557	0.537	0.525	0.520	0.515	0.541	0.524
	Y Current (A)	0.882	0.948	0.943	0.829	0.832	0.742	0.769	0.822	0.807	0.806	0.738	0.674	0.620	0.624	0.626	0.568	0.537	0.505	0.515	0.519	0.505	0.494	0.498	0.501
	B Current (A)	0.948	0.983	1.006	0.953	0.936	0.870	0.904	0.957	0.918	0.889	0.838	0.780	0.730	0.738	0.733	0.681	0.646	0.632	0.614	0.605	0.593	0.587	0.613	0.602
	R Voltage(V)	61.74	61.59	61.79	62.07	62.52	62.79	63.13	63.47	63.88	63.69	63.50	63.69	63.77	64.01	63.93	63.98	64.16	64.06	64.05	64.22	64.36	64.42	64.41	64.50
	Y Voltage(V)	61.61	61.41	61.71	61.93	62.36	62.61	62.95	63.30	63.65	63.46	63.31	63.53	63.57	63.89	63.82	63.88	64.03	63.90	63.93	64.00	64.22	64.32	64.29	64.41
	B Voltage(V)	61.31	61.27	61.41	61.71	62.15	62.41	62.75	63.07	63.40	63.16	62.92	63.15	63.31	63.58	63.49	63.49	63.60	63.49	63.57	63.70	63.81	63.81	63.81	63.87
	Fwd.kWh 3.18864	0.04082	0.04308	0.04394	0.04062	0.04069	0.03737	0.03865	0.04089	0.03998	0.03903	0.03647	0.03420	0.03164	0.03188	0.03176	0.02912	0.02813	0.02688	0.02641	0.02628	0.02587	0.02555	0.02636	0.02604
	Fwd.kVArhlag 0.32998	0.00731	0.00658	0.00596	0.00347	0.00538	0.00524	0.00612	0.00591	0.00426	0.00383	0.00232	0.00115	0.00188	0.00225	0.00228	0.00159	0.00023	0.00031	0.00057	0.00044	0.00046	0.00051	0.00054	0.00066
	Fwd.kVArhlead 0.05694	0.00000	0.00000	0.00000	0.00012	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000	0.00039	0.00095	0.00062	0.00046	0.00038	0.00085	0.00192	0.00179	0.00122	0.00141	0.00127	0.00118	0.00133	0.00118
	Fwd.kVAh 3.24304	0.04163	0.04369	0.04446	0.04091	0.04121	0.03791	0.03933	0.04155	0.04039	0.03938	0.03672	0.03439	0.03182	0.03208	0.03195	0.02932	0.02831	0.02707	0.02653	0.02639	0.02598	0.02565	0.02651	0.02616

Assistant Executive Engineer,
Meter and Relay Test,
TANGEDCO,
Virudhunagar - 626 001.



Schneider Electric India Private Limited

Daily Details

HT SC. No. 389

M/s V.V.V. College, Virudhunagar

Date	Fwd.kVAh	Fwd.kWh	Fwd.kVArhLag	Fwd.kVArhLead	RI	YI	BI	RV	YV	BV
Consumption	0.6517	0.6097	0.0573	0.0718	*	*	*	*	*	*
18/12/2022										
Min.Value	0.0027	0.0018	0.0000	0.0003	0.037	0.058	0.064	62.23	62.38	61.82
Max.Value	0.0088	0.0086	0.0004	0.0019	0.180	0.164	0.217	65.40	65.37	64.96
Consumption	0.5486	0.5047	0.0114	0.1157	*	*	*	*	*	*
19/12/2022										
Min.Value	0.0000	0.0000	0.0000	0.0000	0.048	0.069	0.066	61.34	61.34	61.02
Max.Value	0.0138	0.0132	0.0033	0.0033	0.310	0.309	0.286	65.65	65.62	65.05
Consumption	0.7774	0.7233	0.0387	0.0995	*	*	*	*	*	*
20/12/2022										
Min.Value	0.0026	0.0016	0.0000	0.0000	0.038	0.048	0.063	60.72	60.81	60.44
Max.Value	0.0401	0.0393	0.0096	0.0022	0.845	0.807	0.919	65.53	65.50	64.99
Consumption	1.5487	1.4848	0.1814	0.0667	*	*	*	*	*	*
21/12/2022										
Min.Value	0.0233	0.0231	0.0002	0.0000	0.455	0.433	0.523	61.07	61.04	60.68
Max.Value	0.0777	0.0752	0.0162	0.0014	1.665	1.825	1.585	65.42	65.48	64.99
Consumption	4.1226	4.0463	0.5669	0.0335	*	*	*	*	*	*
22/12/2022										
Min.Value	0.0092	0.0083	0.0000	0.0000	0.223	0.202	0.170	61.23	61.28	60.81
Max.Value	0.0762	0.0744	0.0142	0.0038	1.625	1.614	1.585	65.07	65.00	64.54
Consumption	3.2430	3.1886	0.3300	0.0569	*	*	*	*	*	*
23/12/2022										
Min.Value	0.0248	0.0247	0.0003	0.0000	0.494	0.479	0.570	60.13	60.20	59.91
Max.Value	0.0853	0.0818	0.0222	0.0012	1.827	1.966	1.803	64.96	64.87	64.35
Consumption	4.3210	4.2273	0.6733	0.0173	*	*	*	*	*	*
24/12/2022										
Min.Value	0.0210	0.0206	0.0000	0.0000	0.385	0.425	0.487	60.09	60.15	59.85
Max.Value	0.0672	0.0652	0.0138	0.0031	1.464	1.530	1.467	65.08	65.03	64.58
Consumption	3.4520	3.3991	0.3858	0.0349	*	*	*	*	*	*
25/12/2022										
Min.Value	0.0164	0.0161	0.0000	0.0000	0.356	0.317	0.358	62.49	62.48	62.14
Max.Value	0.0474	0.0470	0.0092	0.0017	0.942	0.948	1.053	65.74	65.69	65.24
Consumption	2.7470	2.7260	0.1744	0.0493	*	*	*	*	*	*

Assistant Executive Engineer,
Meter and Relay Test,
TANGEDCO,
Virudhunagar - 626 001.

Daily Details - 22.12.2022



Schneider Electric India Private Limited

Daily Details

HT SC No. 389
M/s VVV College, VNR

Date	Fwd.kVAh	Fwd.kWh	Fwd.kVAhLag	Fwd.kVAhLead	RI	YI	BI	RV	YV	BV
26/12/2022										
Min.Value	0.0262	0.0261	0.0003	0.0000	0.513	0.490	0.576	61.36	61.32	61.02
Max.Value	0.0843	0.0815	0.0208	0.0019	1.810	1.920	1.765	66.36	66.33	65.90
Consumption	4.6020	4.5044	0.7237	0.0187	*	*	*	*	*	*
27/12/2022										
Min.Value	0.0000	0.0000	0.0000	0.0000	0.517	0.501	0.585	61.59	61.47	61.28
Max.Value	0.0697	0.0683	0.0120	0.0017	1.402	1.580	1.509	65.80	65.76	65.30
Consumption	2.4113	2.3828	0.2628	0.0216	*	*	*	*	*	*
28/12/2022										
Min.Value	0.0252	0.0251	0.0004	0.0000	0.496	0.484	0.563	61.29	61.11	60.97
Max.Value	0.0772	0.0745	0.0186	0.0015	1.635	1.728	1.573	65.78	65.74	65.36
Consumption	4.2728	4.1952	0.6033	0.0176	*	*	*	*	*	*
29/12/2022										
Min.Value	0.0253	0.0252	0.0002	0.0000	0.505	0.471	0.568	60.87	60.90	60.51
Max.Value	0.0807	0.0788	0.0166	0.0017	1.692	1.747	1.724	65.51	65.49	65.06
Consumption	4.2458	4.1622	0.6040	0.0248	*	*	*	*	*	*
30/12/2022										
Min.Value	0.0259	0.0258	0.0002	0.0000	0.510	0.492	0.571	61.06	61.03	60.77
Max.Value	0.0796	0.0771	0.0193	0.0018	1.755	1.800	1.638	65.83	65.76	65.37
Consumption	4.4573	4.3695	0.6444	0.0225	*	*	*	*	*	*
31/12/2022										
Min.Value	0.0204	0.0202	0.0004	0.0000	0.402	0.396	0.464	60.79	60.83	60.41
Max.Value	0.0731	0.0709	0.0161	0.0011	1.589	1.653	1.502	65.14	65.12	64.67
Consumption	3.6139	3.5641	0.3979	0.0293	*	*	*	*	*	*
01/01/2023										
Min.Value	0.0080	0.0063	0.0000	0.0000	0.203	0.218	0.220	62.26	62.38	61.93
Max.Value	0.0487	0.0475	0.0104	0.0047	1.024	0.977	1.060	65.47	65.39	64.90
Consumption	2.5024	2.4730	0.1743	0.0634	*	*	*	*	*	*
02/01/2023										
Min.Value	0.0249	0.0248	0.0008	0.0000	0.485	0.482	0.549	60.99	61.06	60.64
Max.Value	0.0792	0.0758	0.0211	0.0006	1.765	1.799	1.604	65.87	65.80	65.29
Consumption	2.4567	2.3915	0.4246	0.0070	*	*	*	*	*	*

[Signature]
Assistant Executive Engineer,
Meter and Relay Test,
TANGEDCO,
Virudhunagar - 626 001.